



Summit Soil & Water Conservation District

2795 Front Street, Suite D, Cuyahoga Falls, Ohio 44221

phone: 330.929.2871 fax: 330.929.2872

email: staff@summitswcd.org web: summitswcd.org

Target to Resubmit by 5/11/09

April 30, 2009

Mr. Matt Lascola, PE
GPD Associates
520 South Main Street
Akron, OH 44311

Subject: Storm Water Pollution Prevention Plan (SWPPP) review for Haley's Ditch
Remediation/ Restoration – Akron, Ohio

Dear Mr. Lascola,

Cindy Fink and Joan Hug-Anderson, from the Summit SWCD office, reviewed the SWPPP for the plan at the above referenced property. **The SWPPP is not approved.** Our review is based upon Ohio EPA's **SWPPP Checklist for Construction Activities**. Please address the following concerns and re-submit the plan for approval.

PART III.G.1. SITE DESCRIPTION



Page 2 of 2

PART III.G.2.g. NON-SEDIMENT POLLUTANT CONTROLS

- Polychlorinated biphenyls (PCBs) are the focus of the remediation effort on this site.

Include a narrative protocol for the handling and disposal of contaminated soils. This